GOVERNMENT OF ANDHRA PRADESH
ABSTRACT

Home Department – Commissioner of Police, Visakhapatnam City – Sanction of **Rs.25,27,685/-** towards procurement and installation of the electrical safety equipment for all the Government buildings of Police Commissionerate, Visakhapatnam City- Administrative Sanction - Accorded - Orders - Issued.

==========

HOME (BUDGET) DEPARTMENT

G.O.Rt.No.1412 **Dated: 28.08.2025**
Read:

From the Commissioner of Police, Visakhapatnam City,
C.No. 311/B6/2025, Dated:24.02.2025.

&&&&&&

ORDER:

In the reference read above, the Commissioner of Police, Visakhapatnam City has stated that the Electricity Department has conducted fire safety audit of all the Government buildings of Police Commissionerate, Visakhapatnam and suggested for installation of certain required electrical equipment to ensure electrical safety of all buildings of Police Commissionerate, Visakhapatnam. The details of required electrical safety equipment are attached in Annexure to this order.

2. The Commissioner of Police, Visakhapatnam City has requested the Government to sanction an amount of **Rs.25,27,685/-** (Rupees Twenty five lakhs twenty seven thousand and six hundred and eighty five only) to install the necessary electrical safety equipment as suggested by the Electricity Department in order to prevent fire accident due to electrical short circuit or related issues.

3. Government after careful examination hereby accord Administrative Sanction for an amount of **Rs.25,27,685/-** (Rupees Twenty five lakhs twenty seven thousand and six hundred and eighty five only) towards procurement and installation of the recommended electrical safety equipment to mitigate the risk of fire accidents due to electrical short

P.T.O.

circuits or related issues for all the Government buildings of Police Commissionerate, Visakhapatnam City under the Head of Account:**4055-00-207-11-18-520-521.**

4. The Commissioner of Police, Visakhapatnam City shall take necessary action accordingly.

5. This Order is issued with the concurrence of Finance (FMU-H&C)) Department, vide their U.O.No.FIN01-FMU/26/2025-FMU-HC(Computer No: 2822754), Dated:18.08.2025.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF ANDHRA PRADESH)

KUMAR VISHWAJEET
PRINCIPAL SECRETARY TO GOVERNMENT

To
The Commissioner of Police, Visakhapatnam City.
The Director of Treasuries & Accounts, Nidhi Bhavan, Mangalagiri
The Director of Works & Accounts, Nidhi Bhavan, Mangalagiri.
The Pay & Accounts Officer, Nidhi Bhavan, Mangalagiri
The Principal Accountant General, Andhra Pradesh, Vijayawada
Copy to:
Finance (FMU-H&C) Department
P.S. to Minister(Home)
P.S. to Principal Secretary to Government, Home Department.
SF/SC.

//FORWARDED :: BY ORDER//

SECTION OFFICER

[Annexure to the G.O.Rt.No.1412, Home (Budget) Department, dated: 28.08.2025]

The details of required electrical safety equipment.

S.No	Name of the Police Station	Particulars of Equipment	RK Agencies Quotation cost in Rs.
1	Commissioner Office Total all floors	1) Earth Pit cemical 02 Nos 2) 500 Amps fuse cut out 03 Nos 3) 100 Amps Nutrial Link 01 Nos 4) 6 sqmm wire coil 03 Nos	36175/-
2	Commissioner Office Block-2	1) Earth Pit cemical 02 Nos 2) 500 Amps fuse cut out 03 Nos 3) 100 Amps Nutrial Link)1 Nos 4) 6 sqmm wire coil 03 Nos	36175/-
3	Old Commissioner office	1) RCCB 100 Amps 06 Nos 2) 500 Ams fuse cut out 03 Nos 3) 100 Amps nutral link 01 Nos 4) Earth pit cemical 02 Nos 5) 100 Amps 4 pole Isolater 05 Nos 6) Amps 2 pole Isolater 08 Nos 7) 20 Amps MCB 25 Nos 8) 100 Amps Change over 01 Nos	77545/-
4	Camp office Commissioner of Police	1) 100 Amps RCCB 06 Nos 2) Earth pit cemical 02 Nos 3) 6 sqmm wire coil 02 Nos 4) 100 Amps Change over 01 Nos 5) 100 Amps four pole isolator 06 Nos 6) 4sqmm wire coil-02 Nos 7) MCB 20 Amps 10 Nos 8) 10 Amps fuse cut out 03 Nos 9) 100 Amps Nutral link 01 Nos 10) 100 Amps bus bar 01 Nos	90905/-

5	A.R Office Block-01	1) 500 Amps fuse cut out 03 Nos 2) 100 Amps nutural Link 01 Nos 3) 100 Amps RCCB -03 Nos 4) 6 sqmm wire coil-03 nos 5) 4 sqmm wire coil-03 Nos 6) 100 Amps main switch-01 Nos 7) 100 Amps change over -01 Nos 8) Earth Pit cemical 02 Nos 9) 100 Amps 4 pole Isolater 06 Nos 10) 20 Amps MCB 15 Nos 11) 2.5 wire coil -06 Nos 12) 1.5 wire coil -06 Nos	108760/-
6	A.R Office Block-02	1) 500 Amps fuse cut out 03 Nos 2) 100 Amps nutural Link 01 Nos 3) 100 Amps RCCB -08 Nos 4) 6 sqmm wire coil-08 nos 5) 4 sqmm wire coil-08 Nos 6) 100 Amps 4 pole Isolater 08 Nos 7) 20 Amps MCB 40 Nos 8) Earth pit chemicals 02 Nos with copper pipe 9) wooden switch board-04 Nos 10) 100 Amps bus bar 01 Nos 11) 2 pole Isolater 63 Amps 12 Nos	183115/-
7	A.R Office Block-03	1) 100 Amps RCCB 08 Nos 2) 500 Amps fuse cut out 06 Nos 3) 100 Amps Neutral link 02 Nos 4) 6 sqmm wire coil-04 Nos 5) 4 sqmm wire coil-04 Nos 6) 100 Amps 4 pole Inolater 08 Nos 7) 63 Amps 2 pole Isolater 08 Nos 8) 20 Amps MCB 30 Nos 9) Earth pit chemicals 02 Nos with copper pipe & copper plate	137600/-

8	A.R Office Block-04	1) 500 Amps fuse cut out 03 Nos 2) 100 Amps nutural Link 01 Nos 3) 100 Amps RCCB -08 Nos 4) 6 sqmm wire coil-08 nos 5) 4 sqmm wire coil-08 Nos 6) 100 Amps 4 pole Isolater 08 Nos 7) 20 Amps MCB 40 Nos 8) Earth pit chemicals 02 Nos with copper pipe & copper plate 9) wooden switch board-04 Nos 10) 100 Amps bus bar 01 Nos 11) 2 pole Isolater 63 Amps 12 Nos	183115/-
9	A.R Office Block-05	1) 100 Amps RCCB 06 Nos 2) 100 Amps 4 pole Inolater 08 Nos 3) 63 Amps 2 pole Inolater 08 Nos 4) 20 Amps MCB 12 Nos 5) 6 sqmm wire coil 02 Nos 6) 4 sqmm sire coil 02 Nos 7) Earth pit chemicals 02 Nos with copper pipe & copper plate	85500/-
10	A.R Office Block-06	1)Earth pit chemicals 02 Nos with copper pipe & copper plate	9600/-
11	A.R Office Block-07	1) 100 Amps RCCB 01 Nos 2) 200 Amps fure cut out 03 Nos 3) 63 Amps neutral link 01 Nos 4) 100 Amps main switch 01 Nos 5) 100 Amps change over 01 Nos 6) 100 Amps 4 pole Isolater 04 Nos 7) 40 Amps 2 pole Isolater 04 Nos 8) 20 Amps MCB 12 Nos 9) 4sqmm wire coil 04 Nos 10) Earth pit chemicals 02 Nos with copper pipe & copper plate	60310/-

12	A.R Office Block-08	1) 100 Amps RCCB 08 Nos 2) 500 Amps fuse cut out 06 Nos 3) 100 Amps Neutral link 02 Nos 4) 6 sqmm wire coil-04 Nos 5) 4 sqmm wire coil-04 Nos 6) 100 Amps 4 pole Inolater 08 Nos 7) 63 Amps 2 pole Isolater 08 Nos 8) 20 Amps MCB 30 Nos 9) Earth pit chemicals 02 Nos with copper pipe & copper plate	137600/-
13	A.R Office Block-09	1) 100 Amps RCCB 01 Nos 2) Earth pit chemicals 01 Nos with copper pipe & copper plate	11300/-
14	CCS	1) 100 Amps RCCB 02 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate 3) 200 Amps fuse cut out 03 Nos 4) 100 Amps Nuteral link 01 Nos 5) 100 Amps 4 pole Isolater 04 Nos 6) 20 Amps MCB 08 Nos	19425/-
15	M.R Peta P.S	1) 100 Amps RCCB 02 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate 3) 100 Amps 4 pole Isolater 04 Nos 4) 63 Amps 2 pole Isolater 04 Nos 5) 20 Amps MCB 08 Nos	30500/-
16	I Town P.S	1) 100 Amps RCCB 02 Nos 2) 200 Amps fuse cut out 03 Nos 3) 100 Amps Neutral line 01 Nos 4) Earth pit chemicals 02 Nos with copper pipe & copper plate 5) 36 1/2 Four core Armed cable 45 Mts 6) 100 Amps 4 pole Isolater 04 Nos 7) 63 Amps 2 pole Isolater 04 Nos 8) 20 Amps MCB 12 Nos 9) 4sqmm wire coil 04 Nos 10) Meter Board wooden 3 phase 01 Nos	64730/-

17	III Town P.S	1) 100 Amps RCCB 02 Nos 2) 200 Amps fuse cut out 03 Nos 3) 63 Amps Neutral link 01 Nos 4) 4 Pole Isolater 03 Nos 5) 2 pole Isolater 04 Nos 6) MCB 20 Amps 08 Nos 7) Earth pit chemicals 02 Nos with copper pipe & copper plate	33215/-
18	MVP Crime	1) 100 Amps RCCB 02 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate	22600/-
19	IV Town P.S	1) 100 Amps RCCB 02 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate 3) 4 pole Isolater 100 Amps 03 Nos 4) 2 pole Isolater 63 Amps 06 Nos 5) 20 Amps MCB 12 Nos 6) 4sqmm wire coil 02 Nos 7) 200 Amps fuse cut out 03 Nos 8) 63 Amps neutral link 01 Nos	43715/-
20	Dwaraka P.S	1) 100 Amps RCCB 02 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate 3) 4 pole Isolater 100 Amps 03 Nos 4) 2 pole Isolater 63 Amps 06 Nos 5) 20 Amps MCB 12 Nos 6) 4sqmm wire coil 02 Nos 7) 200 Amps fuse cut out 03 Nos 8) 63 Amps neutral link 01 Nos	43715/-
21	Harbour P.S	1) 100 Amps RCCB 02 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate	22600/-

22	Kancharapalem P.S	1) 100 Amps RCCB -02 Nos 2) 12 Modular MCB DP Box 01 Nos 3) 100 Amps 4 pole Isolater 02 Nos 4) 63 Amps 2 pole Isolater 04 Nos 5) 20 Amps MCB 08 Nos 6) 4sqmm wire coil 02 Nos 7) Earth pit chemicals 02 Nos with copper pipe & copper plate	38940/-
23	Malkapuram P.s	1) 100 Amps RCCB 02 Nos 2) 12 modular MCB DP Box 01 Nos 3) 100 Amps 4 pole Isolater 02 Nos 4) 63 Amps 2 pole Isolater 04 Nos 5) 20 Amps MCB 08 Nos 6)4sqmm wire coil 02 Nos 7) Earth pit chemicals 02 Nos with copper pipe & copper plate	38940/-
24	P.M.Palem P.S	1) 100 Amps RCCB 02 Nos 2) 4 pole Isolator 04 Nos 3) 2 pole Isolator 04 Nos 4) 20 Amps MCB 08 Nos 5) Earth pit chemicals 02 Nos with copper pipe & copper plate	30500/-
25	Disha P.S	1) 100 Amps RCCB 02 Nos	13000/-
26	Gopalapatnam P.S	1) 100 Amps RCCB 02 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate 3) 100 Amps 4 pole Isolater 04 Nos 4) 200 Amps Fuse cut out 03 Nos 5) 63 Amps neutral Line 01 Nos 6) 3 phase Nater Board 01 Nos 7) 63 Amps 2 pole Isolater 04 Nos 8) 20 Amps MCB 08 Nos 9) 4sqmm wire coil 04 Nos 10) 2.5 sqmm wire coil 06 Nos 11) 1.5 sqmm wire coil 04 Nos	76530/-

27	Gwajawaka P.S	1) 100 Amps RCCB 04 Nos 2) 3 Phase Mater board 02 Nos 3) 500 Amps Fuse cut out 03 Nos 4) 100 Amps Neutral link 01 Nos 5) copper rod and copper plate with chemical 02 Nos 6) 100 Amps 4 pole Isolater 06 Nos 7) 63 Amps 2 Pole Isolater 06 Nos 8) 20 Amps MCB 20 Nos 9) 6sqmm wire coil 06 Nos 10) 4 sqmm wire coil 06 Nos	122025/-
28	II Town P.S	1) 100 Amps RCCB 02 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate 3) 100 Amps 4 pole Isolater 04 Nos 4) 63 Amps 2 pole Isolater 04 Nos 5) 20 Amps MCB 08 Nos	30500/-
29	New Port P.S	1) 100 Amps RCCB 02 Nos 2) 3 phase mater board 01 Nos 3) 200 Amps fuse cut out 03 Nos 4) 100 Amps neutral link 01 Nos 5) 100 Amps 4 pole Isolater 01 Nos 6) 63 Amps 2 pole Isolater 01 Nos 7) 20 Amps MCB 06 Nos 8) 4 sqmm wire coil 01 Nos 9)Earth pit chemicals 02 Nos with copper pipe & copper plate	33950/-
30	Airlova P.S (OP)	Iron Shead	0

31	Anandapuram P.S	1) 100 Amps RCCB 02 Nos 2) 3 Phase mater board 01 Nos 3) 200 Amps fuse cut out 03 Nos 4) 63 Amps neutral link 01 Nos 5) 12 moduler MCB DP Box 01 Nos 6) 4 pole 100 Amps Isolater 01 Nos 7) 2 pole 63 Amps Isolater 01 Nos 8) 20 Amps MCB 06 Nos 9) 6 sqmm wire coil 03 nos 10) 4 sqmm wire coil 03 Nos 11) Earth pit chemicals 02 Nos with copper pipe & copper plate	64055/-
32	Bheemili P.S	1) 100 Amps RCCB 02 Nos 2) 200 Amps fuse cut out 03 Nos 3) 63 Amps neutral link 01 Nos 4) 12 modular MCB DP Box 01 Nos 5) 4 pole 100 Amps Isolater 01 Nos 6) 2 pole 63 Amps Isolater 01 Nos 7) 20 Amps MCB 06 Nos 8) 6sqmm wirw coil 01 Nos 9) Earth pit chemicals 02 Nos with copper pipe & copper plate	37505/-
33	Padmanabham P.S	1) 100 Amps RCCB 01 Nos 2) 200 Amps fuse cut out 03 Nos 3) 100 Amps Neutral link 01 Nos 4) 6sqmm wire coil 02 Nos 5) 4 sqmm wire coil 01 Nos 6)Earth pit chemicals 02 Nos with copper pipe & copper plate	37425/-

34	Airport P.S	1) 100 Amps RCCB 02 Nos 2) 200 Amps fuse cut out 06 Nos 3) 100 Amps neutral link 02 Nos 4) 3 phase meter board 02 Nos 5) 12 modular MCB DB Box 02 Nos 6) 100 Amps 4 Pole Isolater 04 Nos 7) 63 Amps 2 pole Isolater 04 Nos 8) 20 Amps MCB 12 Nos 9) Earth pit chemicals 02 Nos with copper pipe & copper plate 10) 6 sqmm wire coil 04 Nos 11) 4 sqmm wire coil 04 Nos	86780/-
35	Pendurthi P.S	1) 100 Amps RCCB 02 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate	22600/-
36	Duvvada P.S	1) 100 Amps RCCB 02 Nos 2) 200 Amps fuse cut out 03 Nos 3) 63 Amps Neutral link 01 Nos 4) 100 Amps 4 pole Isolater 01 Nos 5) 20 Amps MCB 04 Nos 6) Earth pit chemicals 02 Nos with copper pipe & copper plate	28265/-
37	Steel Plant P.S	1) 100 Amps RCCB 01 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate	16100/-
38	Police Guest House (Mess)	1) 100 Amps RCCB 06 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate	48600/-

39	Residence of the Commissioner of police	1) 100 Amps RCCB 06 Nos 2) 200 Amps main switch 01 Nos 3) 200 Amps change over 01 Nos 4) 1) 100 Amps RCCB 01 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate 5) 100 Amps 4 pole Isolater 04 Nos 6) 63 Amps 2 pole Isolater 04 Nos 7) 20 Amps MCB 06 Nos 8) 6sqmm wire coil 04 Nos 9) 4 sqmm wire coil 04 Nos	131980/-
40	Police Club (Near Surya bagh)	1) 100 Amps RCCB 02 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate	22600/-
41	New Women's Rest House	1) 100 Amps RCCB 02 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate	22600/-
42	Happy Home	1) 100 Amps RCCB 02 Nos 2) 100 Amps 4 pole Isolater 02 Nos 3) 100 Amps main switch 01 Nos 4) Earth pit chemicals 02 Nos with copper pipe & copper plate	31150/-
43	MT Office	1) 100 Amps RCCB 02 Nos 2) 200 Amps fuse cut out 03 Nos 3) 100 Amps neutral link 01 Nos 4) 100 Amps 4 pole Isolater 01 Nos 5) 63 Amps 2 pole Isolater 01 Nos 6) Earth pit chemicals 02 Nos with copper pipe & copper plate	28150/-
44	New Men waiting Hall	1) 100 Amps RCCB 01 Nos 2) Earth pit chemicals 02 Nos with copper pipe & copper plate 3) 4 sqmm wire coil 02 Nos	24900/-
45	City Task Force Station	1) 100 Amps RCCB 01 Nos 2) Earth pit chemicals 01 Nos with copper pipe & copper plate	11300/-

46	Bheemili Traffice PS	1)100 Amps RCCB 02 Nos 2) 6sqmm wire coil 02 Nos 3) 4sqmm wire coil 02 Nos 4) 20 Amps MCB 06 Nos 5)Earth pit chemicals 01 Nos with copper pipe & copper plate	40650/-
47	Traffice Zone-1 (yendana)	1) 100 Amps RCCB 02 Nos 2) 12 modular MCB DP Box 01 Nos 3) 20 Amps MCB 06 Nos 4) 100 Amps 4 pole Isolater 01 Nos 5) Earth pit chemicals 02 Nos with copper pipe & copper plate 6)200 Amps fuse cut out 03 Nos 7) 100 Amps neutral link 01 Nos 8) 3 phase meter board 01 Nos 9) 6sqmm wire coil 02 Nos	43940/-
48	New Arilova PS	1) 100 Amps RCCB	6500/-
Grand Total:			**25,27,685/-**

KUMAR VISHWAJEET
PRINCIPAL SECRETARY TO GOVERNMENT

//FORWARDED :: BY ORDER//

SECTION OFFICER